The CR4210 and CR4211 Series Current Transducers

# Self Powered AC Current Transducer

### DIN RAIL / PANEL MOUNT, AVERAGE RMS



ISweek www.isweek.com

Add: 16/F, Bldg. #3, Zhongke Mansion, No.1 Hi-Tech S. Rd, Hi-Tech Park South, Shenzhen, Guangdong, 518067 P.R.China

Tel: + 86-755-83289036 Fax: + 86-755-83289052

E-mail: sales@isweek.com

# Self Powered AC Current Transducer

## DIN RAIL / PANEL MOUNT, AVERAGE RMS

#### **SPECIFICATIONS**

Basic Accuracy:	0.5%	Cleaning:	Water-dampened cloth
Linearity:	10% to 100% FS	Output Load:	2K $\Omega$ or Greater
Thermal Drift:	500 PPM/°C	Response Time:	250 ms max., 0-90%FS
Operating Temperature:	0°C to +60°C	Relative Humidity:	80% for temperatures up to
Installation Category:	CAT II		31°C and decreasing linearly to
Vibration Tested To:	IEC 60068-2-6,1995		50% at 40°C
Pollution Degree:	2	Supply Power:	Self powered (output voltage is
Insulation Voltage:	2500 VDC		obtained from current-sensing
Altitude:	2000 meter max.		conductor)
Frequency Range:	50Hz - 400Hz	Torque Specs.:	3.0 inch lbs. (0.4Nm)
Calibration:Average Sensi	ng, RMS Calibrated	Weight:	0.5 lbs.
MTBF:Great	er than 100 K Hours		



1 hole: 0.79(20) Dia. for CR4210 & 4211 (shown)

### **CONNECTION DIAGRAM**



CR4211 Single Element 0 - 10 VDC Output

NOTE: The building installation must have a switch or circuit-breaker that is in close proximity and within easy reach of the operator. The switch or circuit breaker shall be marked as the disconnecting device for the equipment.

**İSweek** www.isweek.com Add: 16/F, Bldg. #3, Zhongke Mansion, No.1 Hi-Tech S. Rd, Hi-Tech Park South, Shenzhen, Guangdong, 518067 P.R.China Tel: + 86-755-83289036 Fax: + 86-755-83289052 E-mail: sales@isweek.com